



Underwriters Laboratories Inc.®

Northbrook, Illinois • (708) 272-8800

Melville, New York • (516) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park,
North Carolina • (919) 549-1400

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 300597-MH15966
ISSUE DATE: May 30, 1997

Issued to: ConVault Inc.
4109 Zeering Rd.
Denair, CA 95316

Report Reference: MH15966, Vol. 1, Sec. 1, Issued 6-4-93


This is to Certify that representative samples of: ConVault Tanks, Protected Type

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 2085, Insulated Aboveground Tanks for Flammable and Combustible Liquids


Additional Information: These secondary containment tanks employ "Venting by Form of Construction" and are evaluated, tested, and marked "Protected," "Vehicle Impact Resistant," and "Projectile resistant." These tanks are for use in accordance with Appendix II-F "Protected Aboveground Tanks for Motor Vehicle Fuel Dispensing Stations Outside of Buildings" of the Uniform Fire Code, published by the International Fire Code Institute, as well as NEPA 30, 30A, and 31. The Listing covers rectangular tanks from 125 to 12,000 gallons. See Owner's Manual for Installation Instructions.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - ; the word "Listed"; a control number (may be alphanumeric) assigned by UL; and, the product or category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Underwriters Laboratories Inc.

Review Engineer: 
Underwriters Laboratories Inc.